



Microbac Laboratories, Inc., Sayre Division
CERTIFICATE OF ANALYSIS

S0J0351

Tioga Central School

Project Name: State Lead Testing

Dave Keene
 P.O. Box 241/3 5th Ave
 Tioga Center, NY 13845

Project / PO Number: N/A
 Received: 10/02/2020
 Reported: 11/05/2020

Analytical Testing Parameters

Client Sample ID:	M.S Art RM Tap 1	Collected By:	Carl Cole-Client
Sample Matrix:	Drinking Water	Collection Date:	09/30/2020 6:00
Lab Sample ID:	S0J0351-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0110	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1644	LLW

Client Sample ID:	M.S Art RM Tap 2	Collected By:	Carl Cole-Client
Sample Matrix:	Drinking Water	Collection Date:	09/30/2020 6:00
Lab Sample ID:	S0J0351-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0234	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1650	LLW

Client Sample ID:	M.S 1st Girls RM A Tap 1	Collected By:	Carl Cole-Client
Sample Matrix:	Drinking Water	Collection Date:	09/30/2020 6:00
Lab Sample ID:	S0J0351-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1651	LLW

Client Sample ID:	M.S 1st Girls RM A Tap 2	Collected By:	Carl Cole-Client
Sample Matrix:	Drinking Water	Collection Date:	09/30/2020 6:00
Lab Sample ID:	S0J0351-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1653	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S RM 108	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:00
Lab Sample ID: S0J0351-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1655	LLW

Client Sample ID: M.S Main Office Kitchen	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:05
Lab Sample ID: S0J0351-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1657	LLW

Client Sample ID: M.S Water Cooler by RM 108	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:05
Lab Sample ID: S0J0351-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1703	LLW

Client Sample ID: M.S Teachers RM	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:05
Lab Sample ID: S0J0351-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1704	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S 1st Boys A Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:10
Lab Sample ID: S0J0351-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1706	LLW

Client Sample ID: M.S 1st Boys A Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:10
Lab Sample ID: S0J0351-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1708	LLW

Client Sample ID: M.S RM 119 Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:10
Lab Sample ID: S0J0351-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1710	LLW

Client Sample ID: M.S RM 119 Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:10
Lab Sample ID: S0J0351-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1714	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S. Handicap RR	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1716	LLW

Client Sample ID: M.S Mens RM	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0051	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1717	LLW

Client Sample ID: M.S Womens RM	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1719	LLW

Client Sample ID: M.S 1st Boys RM B Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1725	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S 1st Boys RM B Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1727	LLW

Client Sample ID: M.S. 1st Girls RM B Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0113	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1729	LLW

Client Sample ID: M.S. 1st Girls RM B Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1731	LLW

Client Sample ID: M.S Girls LKRM	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:25
Lab Sample ID: S0J0351-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		10/29/20 1346	10/29/20 1732	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S Boys LKRM	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:25
Lab Sample ID: S0J0351-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1742	LLW

Client Sample ID: M.S Water Cooler by Girls Gym	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:30
Lab Sample ID: S0J0351-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1747	LLW

Client Sample ID: M.S Water Cooler by Girls Gym 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:30
Lab Sample ID: S0J0351-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1749	LLW

Client Sample ID: M.S Kitchen Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:30
Lab Sample ID: S0J0351-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1751	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S Kitchen Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:30
Lab Sample ID: S0J0351-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1753	LLW

Client Sample ID: M.S Water Cooler Big Cafe	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:30
Lab Sample ID: S0J0351-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1755	LLW

Client Sample ID: M.S. Water Cooler SM Cafe	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:35
Lab Sample ID: S0J0351-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0086	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1801	LLW

Client Sample ID: M.S. Water Cooler by Boys Gym	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:35
Lab Sample ID: S0J0351-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1803	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S. 2nd Girls RM A Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:40
Lab Sample ID: S0J0351-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1804	LLW

Client Sample ID: M.S. 2nd Girls RM A Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:40
Lab Sample ID: S0J0351-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1806	LLW

Client Sample ID: M.S Water Cooler by RM 208	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:10
Lab Sample ID: S0J0351-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0093	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1808	LLW

Client Sample ID: M.S Water Cooler by RM 214	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:10
Lab Sample ID: S0J0351-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1812	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S 2nd Boys RM A Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1814	LLW

Client Sample ID: M.S 2nd Boys RM A Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1816	LLW

Client Sample ID: M.S 2nd Girls RM B Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1818	LLW

Client Sample ID: M.S 2nd Girls RM B Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:15
Lab Sample ID: S0J0351-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1823	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S 2nd Teachers RR	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1825	LLW

Client Sample ID: M.S 2nd Boys RM B Tap 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1827	LLW

Client Sample ID: M.S 2nd Boys RM B Tap 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1829	LLW

Client Sample ID: M.S. Water Cooler by RM 231	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:20
Lab Sample ID: S0J0351-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		10/29/20 1348	10/29/20 1831	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: M.S Water Cooler by RM 235 1	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:25
Lab Sample ID: S0J0351-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0902	LLW

Client Sample ID: M.S Water Cooler by RM 235 2	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:25
Lab Sample ID: S0J0351-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0908	LLW

Client Sample ID: Pre-K RM 1 Sink	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 5:55
Lab Sample ID: S0J0351-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0910	LLW

Client Sample ID: Pre-K RM 1 Water Cooler	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 5:55
Lab Sample ID: S0J0351-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0911	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: Pre-K RM 2 Sink	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:00
Lab Sample ID: S0J0351-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0913	LLW

Client Sample ID: Pre-K RM 2 Water Cooler	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:00
Lab Sample ID: S0J0351-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0915	LLW

Client Sample ID: Pre-K RM 3 Sink	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:00
Lab Sample ID: S0J0351-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0921	LLW

Client Sample ID: Pre-K RM 3 Water Cooler	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:00
Lab Sample ID: S0J0351-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0922	LLW



Microbac Laboratories, Inc., Sayre Division

CERTIFICATE OF ANALYSIS

S0J0351

Client Sample ID: Pre-K Kithcen	Collected By: Carl Cole-Client
Sample Matrix: Drinking Water	Collection Date: 09/30/2020 6:00
Lab Sample ID: S0J0351-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.015 AL	0.0010	mg/L		10/30/20 1351	11/02/20 0928	LLW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Renee Lantz
Customer Relationship Specialist
Reported: 11/05/2020 18:25

Microbac Laboratories, Inc.

2369 Elmira Street | Sayre, PA 18840 | 570-888-0169 p | www.microbac.com



Tioga Central School
PM: Renee Lantz

CHAIN OF CUSTODY RECORD

3821 Buck Dr.
Cortland, NY 13045
607.753.3403

2369 Elmira St., Suite C
Sayre, PA 18840
670.348.0775

428 Route 315 Hwy
Pikition, PA 18640
670.348.0775

4359 Linglestown Rd.
Harrisburg, PA 17112
717.651.9700

3719 Garrett Rd.
Drexel Hill, PA 19026
484.461.9722

Lab Report Address
Client Name: *Tioga Central Schools*
Address: *27 6th Avenue*
City, State, Zip: *Tioga Center NY 13845*
Contact: *DAVE KEENE*
Telephone No.: *607-687-8000*

Invoice Address
Client Name:
Address:
City, State, Zip:
Contact:
Telephone No.:

Turnaround Time
[] Routine (5 to 7 business days)
[] RUSH* (notify lab)

Temperature Upon Receipt (°C)
Therm ID
Holding Time
Samples Received on ice? Yes/No
Custody Seals Intact? Yes/No/NA

Send Report via: [] Mail [X] Fax
E-mail (address): *ccole@tiogacentral.org*
Fax: [] Fax [] e-mail (address)

Results Only [] Level 1 [] Level 2 [] Level 3 [] Level 4 [] EDD
Compliance Monitoring? [] Yes [] No
Agency/Program:

Project: *State Lead Tests*
Location: *State Lead Tests*
Water Dist: *Carl Cole*
Sampler Signature: *Carl Cole*
Sampler Phone No.: *607-761-8075*

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Surface Water (SW), Waste Water (WW), Other (specify)
Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab/Comp	Preservative Type	Requested Analysis	Additional Notes
	Mrs. Ann R. M. TAP 1	9-30-20	6:40 AM	1	DW G	G		Lead	
	" " TAP 2	9-30-20	6:00 AM	1	DW G	G			
	Mrs. 1st Gr. Rm A TAP 1	9-30-20	6:40 AM	1	DW G	G			
	" " TAP 2	9-30-20	6:40 AM	1	DW G	G			
	M.S. Rm 108	9-30-20	6:00 AM	1	DW G	G			
	M.S. Main Office Kitchen	9-30-20	6:05 AM	1	DW G	G			
	M.S. Water Caster by Rm 108	9-30-20	6:05 AM	1	DW G	G			
	M.S. Teachers Rm	9-30-20	6:05 AM	1	DW G	G			
	M.S. 1st Boys A TAP 1	9-30-20	6:10 AM	1	DW G	G			
	" " TAP 2	9-30-20	6:10 AM	1	DW G	G			

Possible Hazard Identification [] Hazardous [] Non-Hazardous [] Radioactive [] Sample Disposition [] Dispose as appropriate [] Return [] Archive
Comments: **PLEASE RETURN SAMPLES ON ICE.**
Relinquished By (signature): *Carl Cole* Date/Time: *10/10/20 8:30 AM*
Relinquished By (signature): *Ann R. M. TAP* Date/Time: *10/12/20 08:30*

CHAIN OF CUSTODY RECORD

3821 Buck Dr. Cortland, NY 13045 807.753.3403
 2369 Elmira St., Suite C Sayre, PA 18840 570.888.0169
 428 Route 315 Hwy Pittston, PA 18840 570.348.0775
 4359 Linglestown Rd. Harrisburg, PA 17112 717.651.9700
 3718 Garrett Rd. Draxel Hill, PA 19026 484.461.9722

Lab Report Address: **27 6th Avenue**
 Client Name: **Tioga Central Schools**
 Address: **27 6th Avenue**
 City, State, Zip: **Tioga Center NY 13845**
 Contact: **Dave Keene**
 Telephone No.: **607-687-8000**
 Invoice Address: **27 6th Avenue**
 Client Name: **Tioga Central Schools**
 Address: **27 6th Avenue**
 City, State, Zip: **Tioga Center NY 13845**
 Contact: **Dave Keene**
 Telephone No.: **607-687-8000**

Send Report via: Mail Fax e-mail (address)
 Project: **State Lead Tests**
 Location: **Water District: Carlisle**
 Sampler Signature: **Carl Cole**
 Sampled by (PRINT): **Carl Cole**
 Compliance Monitoring? Yes No
 Agency/Program: **607-761-8075**


* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab/Comp	Preservative Types	Requested Analysis	Additional Note
	M.S. Boys Locker	9-30-20	6:25 AM	1	DW G	G		Lead	
	M.S. Water Cooler by G-15	9-30-20	6:30 AM	1	DW G	G			
	M.S. Water Cooler by G-15	9-30-20	6:30 AM	1	DW G	G			
	M.S. Kitchen TAP 1	9-30-20	6:30 AM	1	DW G	G			
	" " TAP 2	9-30-20	6:30 AM	1	DW G	G			
	M.S. Water Cooler by CAF	9-30-20	6:30 AM	1	DW G	G			
	M.S. Water Cooler by CAF	9-30-20	6:35 AM	1	DW G	G			
	M.S. Water Cooler by G-15	9-30-20	6:35 AM	1	DW G	G			
	M.S. Girls Rm - TAP 1	10-1-20	6:10 AM	1	DW G	G			
	" " TAP 2	10-1-20	6:10 AM	1	DW G	G			

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive Sample Disposition: Dispose as appropriate Return Archive

Comments: **PLEASE RETURN SAMPLES ON ICE.**

Relinquished By (signature): **Carl Cole** Date/Time: **10/12/2020 8:30**
 Relinquished By (signature): **[Signature]** Date/Time: **10/12/2020 08:30**



Number
Instructions on back

Lab Report Address

Client Name: **Tioga Central Schools**

Address: **27 6th Avenue**

City, State, Zip: **Tioga Center NY 13845**

Contact: **Dave Keene**

Telephone No.: **607-687-8000**

Send Report via: Mail Fax e-mail (address)

Project: **State Lead Tests**

Sampled by (PRINT): **Carl Cole**

Sampler Signature: *Carl Cole*

Sampler Phone No.: **607-761-8075**

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab/Comp	Preservative Type	Additional Note
	M.S. Water Cooler by Rm 208	10-1-20	6:10 AM	1	DW G	G		
	M.S. Water Cooler by Rm 214	10-1-20	6:10 AM	1	DW G	G		
	M.S. 2nd Boys Rm - TAP 1	10-1-20	6:15 AM	1	DW G	G		
	" " TAP 2	10-1-20	6:15 AM	1	DW G	G		
	M.S. 2nd Girls Rm - TAP 1	10-1-20	6:15 AM	1	DW G	G		
	" " TAP 2	10-1-20	6:15 AM	1	DW G	G		
	M.S. 2nd Teachers RR	10-1-20	6:20 AM	1	DW G	G		
	M.S. 2nd Boys Rm - TAP 1	10-1-20	6:20 AM	1	DW G	G		
	" " TAP 2	10-1-20	6:20 AM	1	DW G	G		
	M.S. Water Cooler by Rm 231	10-1-20	6:20 AM	1	DW G	G		

Possible Hazard Identification: Hazardous Non-Hazardous Radioactive

Sample Disposition: Dispose as appropriate Return Archive

Relinquished By (signature) _____ Date/Time _____ Received By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____ Received By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____ Received By (signature) _____ Date/Time _____

PLEASE RETURN SAMPLES ON ICE.



Tioga Central School
PM: Renee Lantz

CHAIN OF CUSTODY RECORD

Number _____
Instructions on back

Lab Report Address

Client Name: Tioga Central Schools

Address: 275th Avenue

City, State, Zip: Tioga Center NY 13845

Contact: Dave Keene

Telephone No.: 607-687-8000

Send Report via: Mail Fax e-mail (address) ccole@tioga-central.org

Project: State Lead Tests

Sampled by (PRINT): Carl Cole

Sampler Signature: Carl Cole

Sampler Phone No.: 607-761-8075

Location: Water District

PO No. _____

Compliance Monitoring? Yes No

(U) Agency/Program _____

* Matrix Types: Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID (Location of sample taken. Ex: Kitchen sink, bathroom sink etc.)	Date Collected	Time Collected	No. of Containers	Matrix	Grab/Comp	Preservative Types	Additional Notes
M	Water Cooler by Rm 136	10-1-20	6:25 AM	1	DW G	G		Lead 200.2 pb
		10-1-20	6:25 AM	1	DW G	G		
	Pre-K Rm 1 Sink	10-1-20	5:55 AM	1	DW G	G		
	Pre-K Rm 1 Water Cooler	10-1-20	5:55 AM	1	DW G	G		
	Pre-K Rm 2 Sink	10-1-20	6:00 AM	1	DW G	G		
	Water Cooler	10-1-20	6:05 AM	1	DW G	G		
	Pre-K Rm 3 Sink	10-1-20	6:00 AM	1	DW G	G		
	Water Cooler	10-1-20	6:00 AM	1	DW G	G		
	Pre-K Kitchen	10-1-20	6:05 AM	1	DW G	G		

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____

PLEASE RETURN SAMPLES ON ICE.

Date/Time _____

Date/Time _____

Date/Time _____

Date/Time _____

Date/Time 10/2/2020

Date/Time 10/2/2020

Date/Time 10/2/2020

Date/Time 10/2/2020



Tioga Central School
PM: Renee Lantz